CCSD Fire Watch Decision Tree

Rev. A - 6/27/08

No Fire Is hot work to be done in an area that has been NO Watch examined and qualifies as a designated area? Required Did the person authorizing the hot work permit advise that a fire watch was necessary? Fire Watch YES Is hot work to be done where a fire might develop? Required Is hot work to be done where flammables or combustibles are more than 35ft away but are easily ignited by sparks? Is hot work to be done where wall or floor openings within 35ft would expose combustibles in adjacent areas? Is hot work to be done where combustibles are adjacent to partitions, ceilings, or roofs being worked on? Are you unsure of any of the "NO" answers for the questions listed above?